



Photo: drip lines at Tucson Botanical Gardens

per day (GPCD). Should a continued reduction of GPCD over time equate to a measurement of conservation? The answer is complicated. Numerous aspects affect a drinking-water supplier's GPCD, such as demographics, climate, economics, and availability of supply. These can change over time to influence GPCD, but the calculation of GPCD itself must remain constant if valid use comparisons are to be made. Yet staffing changes, public-image pressures, and other influences have caused drinking-water suppliers to modify their GPCD calculations, further complicating the evaluation of conservation efforts.

## Need for Standardization

The New Mexico Office of the State Engineer (NMOSE) is charged with administering the state's water resources. It has statutory responsibility over the supervision, measurement, appropriation, and distribution of all surface water and groundwater in the state. As in most southwestern states, municipal use is the principal area of increasing demand. Therefore, to better regulate municipal water use, the agency began to condition municipal water-rights permits with a target GPCD. And, aware of the many ways GPCD calculations can vary, it began a program to standardize them.

## Apples and Oranges

NMOSE first looked at how other states determine GPCD. When the study began in 2007, Florida, Texas, Kansas, and Arizona all were using some form of standard GPCD calculation, for which the primary variables are gallons of water and population. Three of the states researched used total gallons diverted from surface or groundwater prior to treatment or storage, while one used gallons billed to customers. Other states not included in the original research subsequently reported including reuse, raw (diverted water that may have been stored), or diverted water. Two of the original states allowed systems to define their own populations, one used a seasonally adjusted population, while the fourth used the number of living units times a person-per-household average from the U.S. Census Bureau. These may seem like subtle variations but they make a significant difference in the calculation.

Looking within New Mexico, NMOSE found similar variations. Approaches used to estimate population, the most difficult variable to isolate, varied widely. The Census Bureau's population is most commonly used for cities or counties, however political boundaries do not always coincide with water suppliers' service boundaries. Some water providers incorporated miscellaneous populations such as tourists, undocumented workers, and estimated incoming commuter population based on commercial space. Some population figures were reduced based on estimates of homes within the service area having privately owned domestic wells, and connections assumed to be second homes. Other systems used a form of housing units multiplied by persons-per-household, where the latter figures were undocumented, "educated" guesses. These different approaches underscored the need for standardization.

## NMOSE Methodology

NMOSE's goal for a GPCD method focuses on tracking individual water delivery systems rather than comparing GPCD numbers between systems. This requires detailed information that allows each system to be analyzed separately. Therefore, the agency's method provides subcategories of GPCD and requires a standard calculation of populations served. The subcategories include: system total, single-family residential, multi-family residential, CII (commercial, industrial, and institutional), other (as defined by the system), reuse, and non-revenue. The system total calculation is based on the total water diverted; all other categories use billed water except non-revenue, which uses the difference between diverted and billed. The population is calculated as the number of housing units multiplied by the Census Bureau's average persons-per-household for occupied homes within the system's service area. These details allow systems heavily influenced by a large industrial base to be distinguished from those that are primarily residential or that have spikes in commercial use during tourist season.

To assist with the actual calculation, NMOSE developed the GPCD Calculator, a freely downloadable Excel spreadsheet that organizes data entry and automatically calculates each subcategory's GPCD.

# Apples to Apples: A Standardized Measure for Municipal Water

*Cheri Vogel and John Longworth –  
New Mexico Office of the State Engineer*

In the mid 1980s water conservation became a standard by which the New Mexico state engineer evaluated water-rights transfers. In 1997, the state engineer required all water-rights permits to state that the permit "shall not be exercised ... in a manner that is contrary to the conservation of water within the state...". Evaluating whether an applicant is utilizing water in a manner consistent with conservation principles is difficult; ever-evolving conservation technologies and practices add to the challenge.

The most widely recognized metric for water use is gallons per capita

## Lessons Learned

NMOSE pilot-tested the new methodology and calculator with six New Mexico drinking-water systems ranging in size from 116 to 120,000 connections. The tests, as well as comments collected from national water-conservation specialists, allowed the agency to fine-tune the approach.

The review process provided valuable insight into the development of standardized water-use calculations. While no two methods for calculating GPCD are exactly alike, standardization is possible; however NMOSE had to be clear about how the data would be used in order to ease concerns over its regulatory use and each system's public image. Keeping the calculations simple was also key; too many options led to complications and confusion. Defining populations is difficult even with a standard methodology;

**The calculation of GPCD itself must remain constant if valid use comparisons are to be made.**

variations in how connections are defined and multi-family units are counted further confound the issue. Finally, transition time is needed during which utilities may submit their existing GPCD methodology along with the new version.

NMOSE found that the biggest obstacle to fully implementing the new calculator is that drinking-water systems configure their data for customer billing, not water-use accounting. Billing software uses

billing cycles that often do not correlate to calendar months, and bills include adjustments for customer credits or fees. Additionally, when software is updated or water systems are sold, older data may be lost. Finally, internal politics can make it difficult for billing departments to work with engineers, planners, or conservation staff. These problems can be addressed, but require commitment from senior management.

## What's Next?


Since starting the project, NMOSE has been contacted by several state and regional authorities interested in standardizing their GPCD methods. These entities report pressure from elected officials, city managers, and even customers to track their systems' water use. In response, the American Water Works Association (AWWA) and the Alliance for Water Efficiency have teamed up to research and test

methods for tracking water efficiency, including GPCD, in order to establish an accepted repertoire of water-use-efficiency metrics that can be used to uniformly compare use and savings across utilities. The results will be published in the *Journal of AWWA*.

New Mexico's standard methodology was released as a beta version on March 16, 2009. It is now the standard method used for all water-rights permits required to submit a GPCD, and a standard component of water-conservation and water-management plans submitted to NMOSE. It provides the agency with a defensible method for evaluating water use in New Mexico's water-supply systems. ■

NMOSE's GPCD methodology and calculator are available at [www.ose.state.nm.us/wucp\\_gcpd.html](http://www.ose.state.nm.us/wucp_gcpd.html). Contact Cheri Vogel at [cheri.vogel@state.nm.us](mailto:cheri.vogel@state.nm.us).

Annual Analysis of GPCD - Viewer  
(based on Total Population)



The GPCD calculator presents the system total GPCD of a water system divided into sector uses. Note that each sector population is divided by the entire population here; actual sector GPCDs are calculated elsewhere in the program.



# Sustainable Groundwater Resources

Schlumberger Water Services offers a complete range of technologies and services designed to assess and manage groundwater resources in the wake of climate change.

- Groundwater exploration and development
- Water use and supply auditing (balancing and conservation)
- Water quality evaluation and management
- Local, basin, and regional flow investigation and modeling
- Aquifer recharge, storage, and recovery modeling and design
- Advanced geophysical logging and interpretation



[www.water.slb.com](http://www.water.slb.com)  
[sws-services@slb.com](mailto:sws-services@slb.com)

© 2009 Schlumberger. \* Mark of Schlumberger.